

Speaker Profile

- Dr Simon Gant, CEng FIMechE
- Fluid Dynamics Team, Risk Group
- 15 years experience at HSE
- Scientific support to incident investigations, regulation, guidance and standards, consultancy



Flammable mist hazards involving high-flashpoint fluids

Simon Gant^{1*}, Anthony Giles², Richard Bettis¹, Philip Bowen²

¹ Health and Safety Executive (HSE), Harpur Hill, Buxton, UK

² Gas Turbine Research Center (GTRC), Cardiff University, Wales, UK



© British Crown Copyright, 2020

Outline

- Background / motivation
- Aims
- MISTS1 Joint Industry Project
- Updated review of mist incidents
- MISTS2 Joint Industry Project
- Summary

Background / Motivation

- EU ATEX Directive on explosive atmospheres
- Implemented as UK DSEAR Regulations
- Employers must:
 - Identify and classify areas of the workplace where explosive atmospheres may occur
 - Ensure appropriate certified safe equipment is used in the hazardous zones



Background / Motivation

- Guidance on flammable mists from high-flashpoint fluids?
 - BS EN 60079-10-1 Annex D: limited guidance on flammable mists (only qualitative, not quantitative)
 - Energy Institute EI15
 - High-flashpoint fluid mists / sprays treated as Category C Fluids and hazard radii are provided (see next slide), but...
 - “There is little knowledge on the formation of flammable mists and the appropriate extents of associated hazardous areas.”

Energy Institute EI15 Guidance

MODEL CODE OF SAFE PRACTICE PART 15 AREA CLASSIFICATION FOR INSTALLATIONS HANDLING FLAMMABLE FLUIDS

Table C4: Hazard radii R_1 and R_2 for pressurised releases

Fluid category	Release pressure see note 4 (bar(a))	Hazard radius R_1 (m)				Hazard radius R_2 (m)			
		Release hole diameter				Release hole diameter			
		1 mm	2 mm	5 mm	10 mm	1 mm	2 mm	5 mm	10 mm
A	5	2	4	8	14	2	4	16	40
	10	2,5	4	9	16	2,5	4,5	20	50
	50	2,5	5	11	20	3	5,5	20	50
	100	2,5	5	11	22	3	6	20	50
B	5	2	4	8	14	2	4	14	40
	10	2	4	9	16	2,5	4	16	40
	50	2	4	10	19	2,5	5	17	40
	100	2	4	10	20	3	5	17	40
C	5	2	4	8	14	2,5	4	20	50
	10	2,5	4,5	9	17	2,5	4,5	21	50
	50	2,5	5	11	21	3	5,5	21	50
	100	2,5	5	12	22	3	6	21	50
G(i)	5	<1	<1	<1	1,5	<1	<1	1	2
	10	<1	<1	1	2	<1	<1	1,5	3
	50	<1	1	2,5	5	<1	1,5	3,5	7
	100	<1	1,5	4	7	1	2	5	11
G(ii)	5	<1	<1	1,5	3	<1	<1	2	4
	10	<1	1	2	4	<1	1	2,5	5
	50	<1	2	4	8	1	2	6	11
	100	1	2	6	11	2	3	8	14
LNG	1,5	2,5	3	6	10	2	3	7	30
	5	3	5	10	17	2	4	11	40
	10	3	5,5	10	20	2,5	4,5	13	37,5

High-flashpoint mists / sprays treated as Category C fluids




Figure 3.6: Shape factors for pressurised releases

Flammable Mist Incidents

IChemE SYMPOSIUM SERIES NO. 155

Hazards XXI

© 2009 Crown Copyright

MIST FIRES AND EXPLOSIONS – AN INCIDENT SURVEY[†]

R C Santon

Health and Safety Laboratory, Harpur Hill, Buxton, SK17 6PJ

The ignition of mist formed from flammable liquids at temperatures below their flash point is a well known phenomenon. The more frequent consequence of ignition is fire, although a very small number of explosions have often been quoted as examples. A literature survey has exposed a significantly larger number of incidents than had been previously listed. Together with other incident records already noted, a total of 27 relevant records detailing 37 incidents including 20 explosions have been listed. It is notable that nine incidents alone were collectively responsible for a total of 29 fatalities.

The paper includes summaries of all the incidents, and, so far as possible, comments on the fuels and sources of ignition.

Aims of this presentation

- Provide an overview of the work led by HSE on flammable mists over the last decade
- Review records of flammable mist incidents
- Summarise preliminary results from an ongoing joint-industry-funded project

Joint-Industry Project: MISTS 1

- Aims: to undertake scientific research that can be used to develop guidance on:
 - Formation of flammable mist
 - Mitigation measures
 - Area classification zone and extent
 - Protected equipment concepts, and equipment selection


Joint-Industry Project: MISTS 1

- Scope: mists/sprays/aerosols of liquids that are below their flashpoint at ambient temperature
 - Included: Hydraulic oil, lubricating oil, fuel oils, heat transfer fluids, vegetable oil
 - Excluded: flashing fluids (e.g. propane) and low-flashpoint fluids (e.g. gasoline)
- Timescale 2011-2015, budget: £0.5M (\$0.6M)
- Sponsors: HSE, ONR, RIVM, GE, Siemens, EDF/British Energy, RWE, Maersk Oil, Statoil, BP, ConocoPhillips, Nexen, Syngenta, Aero Engine Controls, Atkins, Frazer Nash, Energy Institute

MISTS 1 JIP: Work Packages


1. Literature review
 - When is a mist flammable?
 - How do you generate a flammable mist?
 - Review data on: LEL, MIE, MIC, MESG, MHSIT
 - Mitigation measures
2. Fluids classification
3. Experiments
4. CFD modelling
5. Comparison of CFD to Energy Institute EI15 guidance
6. Development of (tentative) guidance

2. Fluids Classification



Based on 1 mm diameter orifice at 10 bar

3. Experiments at GTRC, Cardiff



3. Experiments at GTRC, Cardiff


- Fluids tested: Jet A1 kerosene, hydraulic oil, light fuel oil
- 1 mm dia, $L/D = 2$, plain circular orifice
- Pressures mostly 5 – 20 barg
- 1 J spark igniter, PDA droplet sizing



Kerosene




Hydraulic oil




3. Experiments at GTRC, Cardiff

Spray Geometry	Fluid	Pressure (barg)	Temperature	Ignited?
Free spray	Jet A1	1.7, 2, 3, 4, 5, 10, 15, 20	Ambient	At all pressures
Free spray	Hydraulic oil	5, 10, 15, 20, 30, 70, 110, 130	Ambient	No, but some “flashes” at highest pressures
Free spray	Light fuel oil	5, 10, 15, 20	Ambient	No
Free spray	Light fuel oil	5, 10, 15, 20	70 °C	At all pressures
Impinging	Hydraulic oil	5, 10, 15, 20	Ambient	No
Impinging	Light fuel oil	15, 20	Ambient	At 20 barg only
Impinging	Light fuel oil	5, 10, 15, 20	70°C	At all pressures

3. Experiments at GTRC, Cardiff



4. CFD Modelling



Droplet
concentration
(kg/m³)

Droplet Sauter
Mean Diameter
(µm)

- DNV Phase III JIP RR droplet size correlation gave results within factor-of-two of measurements for concentration and diameter with Jet A1
- CFD model assumed atomised spray of droplets: poor agreement with non-atomizing hydraulic oil and light fuel oil

5. Comparison of CFD and EI15 guidance






Figure 3.6: Shape factors for pressurised releases




- Results broadly consistent between CFD and EI15
- Hazard range may be larger than given in EI15 for vertically downwards releases, especially at lower pressures

6. Tentative Area Classification Guidelines




Based on 1 mm diameter orifice at 10 bar

6. Tentative Area Classification Guidelines



6. Tentative Area Classification Guidelines



Outline

- Background / motivation
- Aims
- MISTS1 Joint Industry Project
- Updated review of mist incidents
- MISTS2 Joint Industry Project
- Summary

Updated review of incidents

- Aim: to update Santon (2009) review of incidents
- Collaboration: HSE, INERIS, Université de Lorraine
- UK offshore hydrocarbon release database
 - Over period 2016 – 2018: 258 total incidents inc. 25 mists / sprays
- French ARIA incident database
 - 9,725 atmospheric releases: 40 mist / spray incidents
- German ZEMA incident database
 - 464 atmospheric releases: 19 mist / spray incidents

Joint-Industry Project: MISTS 2

- Timescale: 2018-2020
- Sponsors: HSE, Shell, EDF, ONR, Energy Institute, INERIS
- Aims: to address knowledge gaps following MISTS1
- Work packages:
 1. Where does **diesel** fit into the classification scheme?
 2. How does the **hole shape** affect ignitability?
 3. What is the **maximum extent of the flammable zone**?
 4. (Are mist explosions the same as gas explosions?)

Joint-Industry Project: MISTS 2




- Ultra-low sulphur diesel, bio-diesel
- 1 mm dia, $L/D = 2$, plain circular orifice
- 1 J spark igniter, PDA droplet sizing

Findings to date:

- Ultra-low sulphur diesel
 - Ignited at 5 – 20 barg (not at 3 barg)
- Biodiesel
 - Ignited at 20 barg (but not at 5 – 15 barg)




Joint-Industry Project: MISTS 2



Video of 5 barg
ultra-low sulphur
diesel ignition test

Joint-Industry Project: MISTS 2



- Cardiff university soon to start work on Work Package 2: orifice shape
- Currently constructing rig in HSE burn hall for Work Package 3
- Project planned completion Dec 2020

Summary

- Overview provided of:
 - MISTS1 and MISTS2 Joint Industry Projects
 - Mist incident reviews in 2009 and 2019
- MISTS1 findings:
 - Jet A1 kerosene ignited at pressures ≥ 1.7 barg
 - Tentative guidance based Release Classes I - IV
- MISTS2 findings:
 - Diesel ignited at pressures of ≥ 5 barg
 - Work ongoing on orifice shape and zone extent
- Please contact us if you are interested in future work

References

- Santon, R. (2009) "Mist fires and explosions – an incident survey", IChemE Hazards XXI Conference, <https://www.icheme.org/media/9551/xxi-paper-054.pdf>
- Gant, S.E. (2013) "Generation of flammable mists from high flashpoint fluids: literature review", Health and Safety Executive, Research Report RR980 <http://www.hse.gov.uk/research/rrhtm/rr980.htm>
- Bettis R., Burrell G., Gant S.E., Coldrick S., Mouzakitidis K. and Giles A., (2018) "Area classification for oil mists - final report of a Joint Industry Project", HSE Research Report RR1107 <http://www.hse.gov.uk/research/rrhtm/rr1107.htm>
- Lees P., Gant S.E., Bettis R., Vignes A., Lacombe J.-L. and Dufaud O. (2019) "Review of recent incidents involving flammable mists" IChemE Hazards 29 Conference <https://www.icheme.org/media/12613/hazards-29-paper-31-review-of-recent-idents-involving-flammable-mists.pdf>

Thank you

Any Questions?

The work presented here was funded by HSE and the following sponsors: Aero Engine Controls, Atkins, BP, ConocoPhillips, EDF, Energy Institute, Frazer Nash, GE, Maersk Oil, ONR, RIVM, RWE, Shell, Siemens, Statoil and Syngenta. The contents of this presentation, including any opinions and/or conclusions expressed or recommendations made, do not supersede current published HSE policy or guidance.

© British Crown Copyright, 2020